



## Lead and Copper Certified Laboratory Report form


Submit Online: [wqcdcompliance.com/login](http://wqcdcompliance.com/login) (preferred); Fax: (303) 758-1398

WQCD-B2-Drinking Water CAS

4300 Cherry Creek Drive South; Denver, CO 80246-1530

Revision: 11/01/2016

## LCR - Results

Section I System Information (Supplied or Completed by Public Water System)						Section II Certified Laboratory Information (Supplied or Completed by Certified Laboratory)					
PWSID#: CO 0121100			Facility ID: DS001			SDWIS Laboratory ID: CO00049					
System Name: Cascade Metro District #1						Laboratory Name: Accutest Mountain States					
Contact Person: Andre Kilik			Phone: 7196605795			Contact Person: Client Services			Phone: (303)425-6021		
Comments:						Comments:					
						 Scott Heideman      Lab Director      10/12/2018					
						Laboratory Authorized Signature      Printed Name      Title      Date					
Section III (Supplied or Completed by Public Water System)						Section IV (Supplied or Completed by Certified Laboratory)					
Sample Date	Collector	Sample PT ID	Address, City, Zip	Lab Receipt Date	Lab Analysis Date	Lab Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
9/25/2018	AK/D		8025 TOPEKA AVE	9/27/2018	10/1/2018	DA9645-1	Copper	EPA 200.8	1.3	0.002	0.48
9/25/2018	AK/D		8025 TOPEKA AVE	9/27/2018	10/1/2018	DA9645-1	Lead	EPA 200.8	0.015	0.0005	0.0064
Sample Date	Collector	Sample PT ID	Address, City, Zip	Lab Receipt Date	Lab Analysis Date	Lab Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
9/25/2018	AK/D		7835 SEVERY AVE	9/27/2018	10/1/2018	DA9645-2	Copper	EPA 200.8	1.3	0.002	0.1
9/25/2018	AK/D		7835 SEVERY AVE	9/27/2018	10/1/2018	DA9645-2	Lead	EPA 200.8	0.015	0.0005	0.001
Sample Date	Collector	Sample PT ID	Address, City, Zip	Lab Receipt Date	Lab Analysis Date	Lab Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
9/25/2018	AK/D		7720 SEVERY AVE	9/27/2018	10/1/2018	DA9645-3	Copper	EPA 200.8	1.3	0.002	0.094
9/25/2018	AK/D		7720 SEVERY AVE	9/27/2018	10/1/2018	DA9645-3	Lead	EPA 200.8	0.015	0.0005	0.00066
Sample Date	Collector	Sample PT ID	Address, City, Zip	Lab Receipt Date	Lab Analysis Date	Lab Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
9/25/2018	AK/D		4350 HEIZER ST	9/27/2018	10/1/2018	DA9645-4	Copper	EPA 200.8	1.3	0.002	0.29
9/25/2018	AK/D		4350 HEIZER ST	9/27/2018	10/1/2018	DA9645-4	Lead	EPA 200.8	0.015	0.0005	0.00087
Sample Date	Collector	Sample PT ID	Address, City, Zip	Lab Receipt Date	Lab Analysis Date	Lab Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
9/25/2018	AK/D		4645 FOX RD	9/27/2018	10/1/2018	DA9645-5	Copper	EPA 200.8	1.3	0.002	0.15
9/25/2018	AK/D		4645 FOX RD	9/27/2018	10/1/2018	DA9645-5	Lead	EPA 200.8	0.015	0.0005	0.00072
Sample Date	Collector	Sample PT ID	Address, City, Zip	Lab Receipt Date	Lab Analysis Date	Lab Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
9/25/2018	AK/D		7910 FOREST RD	9/27/2018	10/1/2018	DA9645-6	Copper	EPA 200.8	1.3	0.002	0.11
9/25/2018	AK/D		7910 FOREST RD	9/27/2018	10/1/2018	DA9645-6	Lead	EPA 200.8	0.015	0.0005	BDL

NT: Not Tested

Lab MRL: Laboratory Minimum Reporting Level

BDL: Below Laboratory MRL. A less than sign (<) may also be used

mg/L: Milligrams per Liter

AL: Action Level



# Lead and Copper Certified Laboratory Report form


Submit Online: [wqcdcompliance.com/login](http://wqcdcompliance.com/login) (preferred); Fax: (303) 758-1398

WQCD-B2-Drinking Water CAS

Revision: 11/01/2016

4300 Cherry Creek Drive South; Denver, CO 80246-1530

## LCR - Results

Section I System Information (Supplied or Completed by Public Water System)						Section II Certified Laboratory Information (Supplied or Completed by Certified Laboratory)					
PWSID#: CO 0121100			Facility ID: DS001			SDWIS Laboratory ID: CO00049					
System Name: Cascade Metro District #1						Laboratory Name: Accutest Mountain States					
Contact Person: Andre Kilik			Phone: 7196605795			Contact Person: Client Services			Phone: (303)425-6021		
Comments:						Comments:					
						 Scott Heideman      Lab Director      10/12/2018					
						Laboratory Authorized Signature      Printed Name      Title      Date					
Section III (Supplied or Completed by Public Water System)						Section IV (Supplied or Completed by Certified Laboratory)					
Sample Date	Collector	Sample PT ID	Address, City, Zip	Lab Receipt Date	Lab Analysis Date	Lab Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
9/25/2018	AK/D		7925 TEPEKA AVE	9/27/2018	10/1/2018	DA9645-7	Copper	EPA 200.8	1.3	0.002	0.45
9/25/2018	AK/D		7925 TEPEKA AVE	9/27/2018	10/1/2018	DA9645-7	Lead	EPA 200.8	0.015	0.0005	BDL
Sample Date	Collector	Sample PT ID	Address, City, Zip	Lab Receipt Date	Lab Analysis Date	Lab Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
9/25/2018	AK/D		4695 FOX RD	9/27/2018	10/1/2018	DA9645-8	Copper	EPA 200.8	1.3	0.002	0.15
9/25/2018	AK/D		4695 FOX RD	9/27/2018	10/1/2018	DA9645-8	Lead	EPA 200.8	0.015	0.0005	0.00088
Sample Date	Collector	Sample PT ID	Address, City, Zip	Lab Receipt Date	Lab Analysis Date	Lab Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
9/25/2018	AK/D		7890 GERDINER	9/27/2018	10/1/2018	DA9645-9	Copper	EPA 200.8	1.3	0.002	0.16
9/25/2018	AK/D		7890 GERDINER	9/27/2018	10/1/2018	DA9645-9	Lead	EPA 200.8	0.015	0.0005	0.0023
Sample Date	Collector	Sample PT ID	Address, City, Zip	Lab Receipt Date	Lab Analysis Date	Lab Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
9/25/2018	AK/D		4435 HEIZER ST	9/27/2018	10/1/2018	DA9645-10	Copper	EPA 200.8	1.3	0.002	0.1
9/25/2018	AK/D		4435 HEIZER ST	9/27/2018	10/1/2018	DA9645-10	Lead	EPA 200.8	0.015	0.0005	BDL

NT: Not Tested

Lab MRL: Laboratory Minimum Reporting Level

BDL: Below Laboratory MRL. A less than sign (<) may also be used

mg/L: Milligrams per Liter

AL: Action Level